


LEGEND

- EXTERIOR VEHICULAR ACCESS
- - - INTERIOR VEHICULAR ACCESS - 14' CLEAR HEIGHT
- · · · · INTERIOR VEHICULAR ACCESS - 12' CLEAR HEIGHT
- Total Distance (including vertical height difference)
- FIREFIGHTER'S ACCESS ROUTE
- Height Difference (included in total distance)
- EQUIDISTANT ALTERNATIVE ROUTE
- ⊕ SPOT ELEVATIONS ALONG ACCESS ROUTE
- * EGRESS STAIRWAY
- VEHICULAR ACCESS LANE W/ SNOW-MELT SYSTEM
- LOW-RISE BUILDING (1-3 Stories)
- MID-RISE BUILDING (More Than 3 Stories But Not Qualifying As High-Rise)
- LOW/MID-RISE CONSTRUCTED TO COMPLY W/ HIGH-RISE REQS'TS (Due to Limited Accessibility)
- HIGH-RISE BUILDING (Highest Occupied Floor More Than 75' Above Vehicle Access Elev.)



NOTE: FOR ADDITIONAL INFORMATION SEE THE LETTER OF UNDERSTANDING BETWEEN THE DEVELOPER, PARK CITY FIRE MARSHAL, AND PARK CITY FIRE SERVICE DISTRICT TITLED "TREASURE HILL - PHASE 3 FIRE PROTECTION MASTER PLAN DEVELOPMENT" DATED 1/9/04.